

FICHA TECNICA VISOR ACUSTICO IS/46

Propietario del programa: AAA
 Margen de error = ± 3 dB
 Cliente:
 Resultado de la verificación:


Visor Acustico IS/46
 Informe N°:
 Fecha:
 Local:



$R_w = 50$ dB

**100 - 3150
 C -1
 Ctr -7**

Frecuencias	dB
50	28
63	22,1
80	20,5
100	26,1
125	31,1
160	35,1
200	38,3
250	41,1
315	43,7
400	46
500	48,1
630	50
800	51,6
1000	53,1
1250	53,5
1600	51,3
2000	58,5
2500	63,1
3150	67,4
4000	71,7
5000	75,8
R_w	50
C	-1
Ctr	-7



$R_A = 49$ dB(A)